

# DECLARATION LETTER

We hereby declare that GoodWe inverters listed below have built-in DC disconnect in compliance with the requirements specified in AS/NZS5033:2014 Amd 1+Amd 2, Clause 4.4.1.2

<b>DNS Series</b>	<b>GW3000D-NS, GW3600D-NS, GW4200D-NS GW5000D-NS, GW6000D-NS</b>
<b>EH Series</b>	<b>GW3600-EH, GW5000-EH, GW6000-EH</b>
<b>MS Series</b>	<b>GW5000-MS, GW6000-MS, GW7000-MS, GW8500-MS, GW9000-MS, GW10K-MS</b>
<b>SMT Series</b>	<b>GW25K-MT, GW29.9K-MT, GW36K-MT</b>

## Note

1. Inverter should be installed according to the manufacturer instruction as required by AS/NZS3000:2018, and its working conditions should be in compliance with the requirements in the inverter user manual.
2. The maximum voltage and current that the built-in DC disconnect

# DECLARATION LETTER

can tolerate at ambient temperature  $70^{\circ}\text{C}$  equals to the maximum input voltage and short-circuit current in the specification of the inverter.

Declared by Jiangsu GoodWe Power Supply Technology Co., Ltd

Authorized Signature:



Date: April 08, 2020